

CERTIFICATE OF ACKNOWLEDGMENT OF RECEIPT OF ADDENDUM

THE CITY OF READING

ADDENDUM NO. 1

RFP: 3rd and Spruce HVAC Improvements

DUE DATE: September 21, 2022
3:00 P.M. Prevailing Time

This addendum must be signed, attached to, and returned with your proposal to the City of Reading by the time and date indicated ABOVE.

- Q1. Will 2300 specifications be issued?
- A1. This appears to be a typo as they are referencing another spec?
- Q2. Is there an estimate for the HVAC work?
- A2. We are not releasing this information
- Q3. Will the Wage Determination Sheet be attached?
- A3. Yes – see attachment ([Prevailing Wage Project \(pa.gov\)](#))
- Q4. Drawing M200 shows registers marked RA and RR. These are not showing in the mechanical schedule on drawing M300. Will the GRD schedule be updated?
- A4. These should be read to say “RG”.
- Q5. Some of the CFMs shown on drawing M200 do not correspond with the CFMs listed in the schedule. Will they be corrected?
- A5. In case of discrepancy between floor plans and schedules regarding supply air to rooms, the floor plans shall govern.
- Q6. It was mentioned at the pre bid that there is an issue with the heat/cooling in storage room near the kitchen where food is kept/prepared. Will the architect/engineer be sending out directions/clarifications on what is to be done in that area to correct the problem?
- A6. This area will be properly conditioned by new VAV boxes VAV-6-61 thru 6-3 shown on the drawings.

Q7. Who is responsible for parching and painting old penetrations in walls once the duct is demoed?

A7. The Mechanical Contractor shall patch any unused existing openings to match adjacent to satisfaction of the City of Reading.

I, HEREBY CERTIFY THAT THE CHANGES COVERED BY THIS ADDENDUM HAVE BEEN TAKEN INTO ACCOUNT.

Firm Name (Type or Print) _____

Authorized Signature _____

Title _____

Name (Type or Print) _____

Date _____