

CERTIFICATE OF ACKNOWLEDGMENT OF RECEIPT OF ADDENDUM

THE CITY OF READING

ADDENDUM NO. 2

RFP: 9th and Marion Fire Station Re-bid
Mechanical Construction

DUE DATE: October 11, 2021
3:00 P.M. Prevailing Time

This addendum must be signed, attached to, and returned with your proposal to the City of Reading by the time and date indicated ABOVE.

THE NEW DUE DATE FOR THIS PROJECT IS 3:00 PM, PREVAILING TIME, ON MONDAY, OCTOBER 18, 2021.

Q1. Have any of the other VRF manufacturer's been approved from the original bid? There won't be enough time to go through the substitution process.

A1. There won't be enough time to go through the substitution process.

Q2. Is there a preferred controls contractor?

A2. No

Q3. Please confirm Professional Liability Insurance is required for the Mechanical Contractor.

As a contractor that installs as per plans and specs this type of insurance does not normally apply.

A3. Yes, Professional Liability Insurance is required.

Q4. What is the estimated cost of this bid?

A4. Approximately \$800,000

- Q5. We cannot find reference to EQ 2, 4 and 7. Clarify what this equipment is.
- A5. EQ-2 is a 6 unit turnout gear dryer. EQ-4 is a commercial turnout gear extractor. EQ-7 is a domestic grade clothes drying machine. The name, description, model, and which prime contract has ownership of each piece of equipment is indicated in the EQUIPMENT SCHEDULE on sheets A114 and A115.

I, HEREBY CERTIFY THAT THE CHANGES COVERED BY THIS ADDENDUM HAVE BEEN TAKEN INTO ACCOUNT.

Firm Name (Type or Print)_____

Authorized Signature _____

Title_____

Name (Type or Print)_____

Date_____