

**CERTIFICATE OF ACKNOWLEDGMENT OF RECEIPT OF ADDENDUM**

**THE CITY OF READING**

**ADDENDUM NO. 2**

**RFP: Baer Park Playground Improvements**

**DUE DATE:** December 14, 2022  
3:00 P.M. Prevailing Time

This addendum must be signed, attached to, and returned with your proposal to the City of Reading by the time and date indicated ABOVE.

Q1. May we have a range of probable cost?

A1. \$550,000

Q2. Is the pre bid mandatory or non-mandatory? It says both under the description tab.

A2. The prebid meeting was held 11/8/2022 and was non-mandatory.

Q3. Can PDF drawings and CAD files be provided?

A3. The drawings are now available on Pennbid.

Q4. Can we determine the quantities of furnishings and size of the project?

A4. Items are listed within the drawings

Q5. Can the engineer post a design for the 3 lighting pole foundations that are proposed to be installed?

A5. Detail 206 on the drawings

Q6. Summary of Work (spec 011000) calls out for tree work. Plans do not show any tree work. Please clearly define any tree work or advise if none is required.

A6. Plans show the instillation of trees in the rain garden refer to plant schedule C701

Q7. Electric Service Notes on Drawing C300 indicates that there are 4 lights to be installed. I only am able to find 3 new lights on the drawing, where is the 4th located?

A7. Typical of 3 was specified in the drawings please price 3

Q8. Also are any of the existing lighting poles being removed or are they to be integrated with the new lights to be installed?

A8. There are no existing light poles in this area

I, HEREBY CERTIFY THAT THE CHANGES COVERED BY THIS ADDENDUM HAVE BEEN TAKEN INTO ACCOUNT.

Firm Name (Type or Print)\_\_\_\_\_

Authorized Signature \_\_\_\_\_

Title\_\_\_\_\_

Name (Type or Print)\_\_\_\_\_

Date\_\_\_\_\_